

**OFFICE OF THE SENIOR GEOLOGIST
GROUND WATER SURVEY AND DEVELOPMENT AUTHORITY
ADMINISTRATIVE BHAVAN CHANDRAPUR**

E-mail-srgeochandrapur@gmail.com

Telephone No 07172/250715

Out Ward No: SG/GWDA/Ch/Lab/973/2025

Dated 09/09/2025

To,

Principal,
Stella Maris Convent & Junior College,
Korpana, Tah Korpana, Dist Chandrapur

Sub: Organic testing report of the drinking water (Private sample)

Ref: Your letter 69/2025 dated 02/09/2025 and the receipt no 131 dated 11/09/2025 received through you.


As per the above referred subject you had sent 3 samples of drinking water from Stella Maris Convent and Junior College, Village Korpana, Tahsil Korpna for organic testing report to the district laboratory has been received and the Organic quality testing report of the said water sample is enclosed along with this report.

Encl: Testing report of the water sample as above.

Sd/- illegible
Senior Geologist
Ground Water survey and development Authority
Chandrapur

This is to certify that the above is the true English translation of the accompanying document in Marathi language.

Chandrapur,
Dated: 19/09/2025


Dr. Lalji James,
Advocate, Chandrapur
Dr. LALJI JAMES
ADVOCATE
CHANDRAPUR (M.S.)



**DISTRICT WATER QUALITY TESTING LABORATORY
GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, CHANDRAPUR
DIST. CHANDRAPUR REGION NAGPUR**

E-Mail : srgeochandrapur@gmail.com

Phone No. : 07172-299508

TEST REPORT

TEST REPORT		
Issued To :	Principal, Stella Maris Convrnt & Jr. College, Korpana Ta. Korpana Dist. Chandrapur	
Report Issued Dated :	15.09.2025	Report No: DWTL/CHN/06/09/2025
Sample ID No: DWTL/CHN/06/09/2025	Type of source:- Tap-1	

SAMPLE PARTICULARS				
Sample type	Water (Drinking Water)	Date of Start of Analysis	11.09.2025	
Sample collected by	Customer	Date of Completion of Analysis	15.09.2025	
Date of Receipt of Sample	11.09.2025	Environmental Conditions (Lab)	Temp. (°C) :	26°C ± 5 °C
Sample Quantity	200 ml		Humidity (%):	46% ± 10%
Source Location	In Stella Maris Convrnt & Jr. College, Korpana Ta. Korpana	Discipline	Bacteriological	


WATER TEST RESULTS FOR NON ACCREDITED PARAMETERS

Sr. No.	Test Parameter	Unit	Test Method	Test Results	Requirement as per IS10500 : 2012 (Drinking Water Specifications)	
					Desirable Limit	Permissible Limit
1	Total Coliforms	MPN	Multiple Tube Dilution technique	2.0	16	-

End of Test Report

Remarks :

- The results relate only to the samples tested..
- The report shall not be reproduced except in full, without the written approval of the laboratory.
- The Sample is collected by the client himself. As such the laboratory has no involvement in sample collection.


Shri. Mahendra N. Walde
(TM/Chemist)


Smt. Sonali D. Ingle
(QM/ Authorized Signatory)



DISTRICT WATER QUALITY TESTING LABORATORY
GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, CHANDRAPUR
DIST. CHANDRAPUR REGION NAGPUR

E-Mail : srgeochandrapur@gmail.com

Phone No. : 07172-299508

TEST REPORT

Issued To :	Principal, Stella Maris Convent & Jr. College, Korpana Ta. Korpana Dist. Chandrapur
Report Issued Dated :	15.09.2025
Sample ID No: DWTL/CHN/08/09/2025	Report No: DWTL/CHN/08/09/2025
	Type of source:- Tap-3

SAMPLE PARTICULARS

Sample type	Water (Drinking Water)	Date of Start of Analysis	11.09.2025
Sample collected by	Customer	Date of Completion of Analysis	15.09.2025
Date of Receipt of Sample	11.09.2025	Environmental Conditions (Lab)	Temp. (°C) : 26°C ± 5 °C
Sample Quantity	200 ml		Humidity (%): 46% ± 10%
Source Location	In Stella Maris Convent & Jr. College, Korpana Ta. Korpana	Discipline	Bacteriological


WATER TEST RESULTS FOR NON ACCREDITED PARAMETERS


Sr N o.	Test Parameter	Unit	Test Method	Test Results	Requirement as per IS10500 : 2012 (Drinking Water Specifications)	
					Desirable Limit	Permissible Limit
1	Total Coliforms	MPN	Multiple Tube Dilution technique	1.0	16	-

End of Test Report

Remarks :

- The results relate only to the samples tested..
- The report shall not be reproduced except in full, without the written approval of the laboratory.
- The Sample is collected by the client himself. As such the laboratory has no involvement in sample collection.


Shri. Mahendra N. Walde
(TM/Chemist)


Smt. Sonali D. Ingle
(QM/ Authorized Signatory)



DISTRICT WATER QUALITY TESTING LABORATORY
GROUNDWATER SURVEYS & DEVELOPMENT AGENCY, CHANDRAPUR
DIST. CHANDRAPUR REGION NAGPUR

E-Mail : srgcochandrapur@gmail.com

Phone No. : 07172-299508

TEST REPORT

Issued To :	Principal, Stella Maria Convent & Jr. College, Korpana Ta. Korpana Dist. Chandrapur		
Report Issued Dated :	15.09.2025	Report No:	DWTL/CHN/07/09/2025
Sample ID No:	DWTL/CHN/07/09/2025	Type of source:-	Tap-2

SAMPLE PARTICULARS			
Sample type	Water (Drinking Water)	Date of Start of Analysis	11.09.2025
Sample collected by	Customer	Date of Completion of Analysis	15.09.2025
Date of Receipt of Sample	11.09.2025	Environmental Conditions (Lab)	Temp. (°C) : 26°C ± 5 °C
Sample Quantity	200 ml		Humidity (%): 46% ± 10%
Source Location	In Stella Maria Convent & Jr. College, Korpana Ta. Korpana	Discipline	Bacteriological


WATER TEST RESULTS FOR NON ACCREDITED PARAMETERS


Sr No.	Test Parameter	Unit	Test Method	Test Results	Requirement as per IS10500 : 2012 (Drinking Water Specifications)	
					Desirable Limit	Permissible Limit
1	Total Coliforms	MPN	Multiple Tube Dilution technique	1.0	16	-

End of Test Report

Remarks :

- The results relate only to the samples tested..
- The report shall not be reproduced except in full, without the written approval of the laboratory.
- The Sample is collected by the client himself. As such the laboratory has no involvement in sample collection.


Shri. Mahendra N. Walde
(TM/Chemist)


Smt. Sonali D. Ingle
(QM/ Authorized Signatory)

OFFICE OF THE GRAM PANCHAYAT KATALABODI

P S Korpana

Z.P. Chandrapur

Out Ward No 30/2025

Date: 17/9/2025

CERTIFICATE

Round seal of the
Gram Panchayat
Katalabodi with
date as 9/9/2025

This is to certify from the village Gram Panchayat Katalabodi that, the school named as Stella Maris Convent and Junior College, Korpana is within the jurisdiction of Group Gram Panchayat Dhoptala and the entire rooms in the school /building and school premises has been sanitized.

Hence this certificate.

Sd/- illegible
Sarpanch
Gram Panchayat, Katalabodi

Sd/- illegible
secretary
Gram Panchayat, Katalabodi

This is to certify that the above is the true English translation of the accompanying document in Marathi language.

Dr. Lalji James,
Advocate, Chandrapur.

Chandrapur,
Dated: 19/09/2025

Dr. LALJI JAMES
ADVOCATE
CHANDRAPUR (M.S.)

कार्यालय ग्राम पंचायत कातलाबोडी

पं.स. कोरपना.

जि.प. चंद्रपूर


जा. क्र. 301
2025




प्रमाणपत्र

मौजा ग्राम पंचायत कातलाबोडी कडून प्रमाणपत्र देण्यात येते कि, स्टेला मॉरिस कॉनवेंट अंड जुनिअर कॉलेज, कोरपना हि शाळा ग्राम पंचायत गट ग्रामपंचायत धोपटाळा हद्दीत येत असून या शाळेतील सर्व रूम / ,ईमारत व शाळेतील परिसर सॅनिटायझर धुळ फवारणी केली आहे.

करिता प्रमाणपत्र देण्यात येत आहे.


सरपंच
ग्राम पंचायत कातलाबोडी


ग्रामपंचायत अधिकारी
ग्राम पंचायत कातलाबोडी